

CHN 使用说明书

感谢您购买欧姆龙E5EC-T数字式控制器。
本说明书描述了产品的功能、性能以及充分发挥产品使用效果的应用方法。

请在使用该产品时注意以下事项：

- 使用该产品的人必须具备足够的电气系统知识。
- 在使用该产品前应通读并理解本说明书以确保正确的使用。
- 妥善保管该说明书以确保在需要时可以随时查阅。

欧姆龙公司

©All Rights Reserved

有关详细的应用步骤, 请参阅《E5□C-T数字式控制器用户手册》(Cat. No. H188)。

安全注意事项

● 警告符号的要点

表示潜在的危险情况, 如不加以防止, 很可能导致轻度或中度的人身伤害或财产损坏。在使用该产品前应仔细阅读本说明书。


表示可能造成控制操作失效或阻止报警输出, 导致财产损失。为了在控制器发生误动作时确保安全, 应采取适当的安全措施, 如使用单独的线路安装监控设备。

详见产品规格书中保证及免责事项内容。


5377457-6A

接线


● 尺寸规格




● 安装



● 连接 (端子适用性因机器型号而异) 请勿在灰色端子上连接任何器件。



● 前面板的元件名称



动作显示
• SUB1~4: 显示辅助输出1~4
• OUT1~2: 显示控制输出1~2
• 线性电流输出时, 0%输出以外均亮灯。
• TUNE: 显示程序No.、分段No.、分段剩余时间或操作量 (阀门开度)。
• FSP: 恒定SP模式为开启状态时亮灯。
• RST: 程序复位中亮灯。
• CMW: 当通信写入允许时点亮, 禁止时熄灭。
• ON: 当设置变更保护为ON (禁用向上、向下键) 时点亮。
• MANU: 手动模式时亮灯。
• HOLD: 程序保持中亮灯。
• WAIT: 程序待机中亮灯。

● 操作菜单

● 输入类型

输入类型	输入	设定	设定范围
铂电阻温度计	Pt100	0 ~ -200 ~ 850	-300 ~ 1500
	1 ~ -199.9 ~ 500.0	-199.9 ~ 900.0	
	2 ~ 0.0 ~ 100.0	0 ~ 210.0	
	3 ~ -199.9 ~ 500.0	-199.9 ~ 900.0	
	4 ~ 0.0 ~ 100.0	0 ~ 210.0	
热电偶	K	-5 ~ 200 ~ 1300	-300 ~ 2300
	6 ~ -20.0 ~ 500.0	0 ~ 900.0	
	J	-7 ~ 100 ~ 850	-100 ~ 1500
	T	8 ~ 200 ~ 400.0	0 ~ 750.0
	9 ~ 200 ~ 400	-300 ~ 700	
	10 ~ -199.9 ~ 400.0	-199.9 ~ 700.0	
	E	11 ~ 200 ~ 600	-300 ~ 1100
	L	12 ~ -100 ~ 850	-100 ~ 1500
	U	13 ~ 200 ~ 400	-300 ~ 700
	N	14 ~ -199.9 ~ 400.0	-199.9 ~ 700.0
	R	15 ~ 200 ~ 1300	-300 ~ 2300
	S	16 ~ 0 ~ 1700	0 ~ 3000
	B	17 ~ 0 ~ 1700	0 ~ 3000
	W	18 ~ 100 ~ 1800	300 ~ 3200
	V	19 ~ 0 ~ 2300	0 ~ 3200
	PL II	20 ~ 0 ~ 1300	0 ~ 2300
红外温度传感器	ES1B	10~70°C	21 ~ 0~90
		60~120°C	22 ~ 0~120
		115~165°C	23 ~ 0~165
		140~260°C	24 ~ 0~260
电流输入		4~20 mA	25 对比偏移量可采用下列范围: -1999~-999.9, -19.99~-9.99, 1~5 V
		0~20 mA	26
		1~5 V	27 -1.999~-0.999
		0~5 V	28
		0~10 V	29

默认值是“0”。

* 当输入类型不是铂电阻时错误的将铂电阻接入时, 将会显示SERP。若要清除SERP显示, 需要正确接线并重新上电。

● 报警

设定	报警类型	报警输出功能
	正报警值 (X)	负报警值 (X)
0	无报警功能	无输出
1	偏差上/下限	根据L, H值的不同而不同
2	偏差上限	根据L, H值的不同而不同
3	偏差下限	根据L, H值的不同而不同
4	偏差上/下范围	根据L, H值的不同而不同
5	偏差上/下限待机序列ON	根据L, H值的不同而不同
6	偏差上限待机序列ON	根据L, H值的不同而不同
7	偏差下限待机序列ON	根据L, H值的不同而不同
8	绝对值上限	根据L, H值的不同而不同
9	绝对值下限	根据L, H值的不同而不同
10	绝对值上/下限待机序列ON	根据L, H值的不同而不同
11	绝对值下限待机序列ON	根据L, H值的不同而不同
12	LBA (仅对报警1)	
13	PV变化率报警	
14	SP绝对值上限	ON OFF 0 0
15	SP绝对值下限	ON OFF 0 0
16	MV绝对值上限	ON OFF 0 0
17	MV绝对值下限	ON OFF 0 0

* 默认的报警类型为“2”。

* 1: 要使参数1, 4和5提供不同的报警类型, 可对其设定上限与下限。下限和上限分别用字母L和H指示。

* 2: 关于输入类型和报警类型的项目, 请参考上面的表格。

* 3: 只有参数“N5: 温度输入偏移”中的设定值应用于整个温度输入范围。如果输入偏移值设定为1.2°C, 则过程值为200°C时, 经过输入偏移后按照201.2°C处理。而如果输入偏移值设定为-1.2°C, 则经过输入偏移后过程值按照198.8°C处理。

* 4: 当转至初始设定菜单时运行停止。(控制/报警均停止。)

* 根据型号和设定的不同, 有些灰色的设定项目可能不显示。

● 警告符号

● 警告

通电期间, 请勿接触端子。

否则会触电而导致轻伤。

不得让金属物体、导线或安装时产生的切屑或湿气进入控制器、调试工具端口或调试工具电缆连接器的开口处。否则会导致触电、火灾或机器误动作。在不将封盖用于防止异物进入端口时, 请将其取下。

请勿将本产品用于易燃易爆气体的场合。否则可能因为爆炸而造成轻度伤害。

绝对不要拆卸、改装以及修理该产品或接触任何内部元件。否则会导致轻微触电、火灾或机器误动作。

注意一火灾或触电的危险。

a) 该产品为UL列表的开放型过程控制设备, 必须安装在能够防止火花进出的机壳中。

b) 在使用两个以上断电开关的情况下, 维修前请先断开所有开关, 确保本产品处于断电状态。

c) 信号输出为SELV (安全低电压电源), 回路受限。

d) 注意: 为了减少火灾或触电的危险, 请勿将不同的2类回路的输出互连。

如果输出继电器超过了预期的使用寿命, 有时会发生触点熔化或燃烧。始终要注意输出继电器的应用环境, 并在额定负载及预期寿命以内使用。输出继电器的预期寿命随着输出负载以及开关条件的变化而变化。

松动的端子可能导致火灾。请以指定的0.43~0.58 N·m的扭矩拧紧螺丝。

请设定适合系统控制用的产品参数。如果设定不当, 可能会因意外操作而造成财产损失或事故。

控制器误动作很可能造成控制操作失效或阻止报警输出, 导致财产损失。为了在控制器发生误动作时确保安全, 应采取适当的安全措施, 如使用单独的线路安装监控设备。

● 警告

通电期间, 请勿接触端子。

否则会触电而导致轻伤。

不得让金属物体、导线或安装时产生的切屑或湿气进入控制器、调试工具端口或调试工具电缆连接器的开口处。否则会导致触电、火灾或机器误动作。在不将封盖用于防止异物进入端口时, 请将其取下。

请勿将本产品用于易燃易爆气体的场合。否则可能因为爆炸而造成轻度伤害。

绝对不要拆卸、改装以及修理该产品或接触任何内部元件。否则会导致轻微触电、火灾或机器误动作。

注意一火灾或触电的危险。

a) 该产品为UL列表的开放型过程控制设备, 必须安装在能够防止火花进出的机壳中。

b) 在使用两个以上断电开关的情况下, 维修前请先断开所有开关, 确保本产品处于断电状态。

c) 信号输出为SELV (安全低电压电源), 回路受限。

d) 注意: 为了减少火灾或触电的危险, 请勿将不同的2类回路的输出互连。

如果输出继电器超过了预期的使用寿命, 有时会发生触点熔化或燃烧。始终要注意输出继电器的应用环境, 并在额定负载及预期寿命以内使用。输出继电器的预期寿命随着输出负载以及开关条件的变化而变化。

松动的端子可能导致火灾。请以指定的0.43~0.58 N·m的扭矩拧紧螺丝。

请设定适合系统控制用的产品参数。如果设定不当, 可能会因意外操作而造成财产损失或事故。

控制器误动作很可能造成控制操作失效或阻止报警输出, 导致财产损失。为了在控制器发生误动作时确保安全, 应采取适当的安全措施, 如使用单独的线路安装监控设备。

● 警告

通电期间, 请勿接触端子。

否则会触电而导致轻伤。

不得让金属物体、导线或安装时产生的切屑或湿气进入控制器、调试工具端口或调试工具电缆连接器的开口处。否则会导致触电、火灾或机器误动作。在不将封盖用于防止异物进入端口时, 请将其取下。

请勿将本产品用于易燃易爆气体的场合。否则可能因为爆炸而造成轻度伤害。

绝对不要拆卸、改装以及修理该产品或接触任何内部元件。否则会导致轻微触电、火灾或机器误动作。

注意一火灾或触电的危险。

a) 该产品为UL列表的开放型过程控制设备, 必须安装在能够防止火花进出的机壳中。

b) 在使用两个以上断电开关的情况下, 维修前请先断开所有开关, 确保本产品处于断电状态。

c) 信号输出为SELV (安全低电压电源), 回路受限。

EN INSTRUCTION MANUAL

Thank you for purchasing the OMRON E5EC-T Digital Controller. This manual describes the functions, performance, and application methods needed for optimum use of the product. Please observe the following items when using the product.

- This product is designed for use by qualified personnel with a knowledge of electrical systems.
- Before using the product, thoroughly read and understand this manual to ensure correct use.
- Keep this manual in a safe location so that it is available for reference whenever required.


OMRON Corporation
©All Rights Reserved

Refer to the E5EC-T Digital Controllers User's Manual (Cat. No. H185) for detailed application procedures.

Safety Precautions


CAUTION Indicates a potentially hazardous situation which, if not avoided, is likely to result in minor or moderate injury or property damage. Read this manual carefully before using the product.

Wiring Dimensions



- * Do not remove the terminal block. Doing so may result in failure or malfunction.
- * Setup Tool ports are provided on the top and front of the Digital Controller. Use these ports to connect a personal computer to the Digital Controller when using the Setup Tool. The E58-CIFQ2-E USB-Serial Conversion Cable is required to connect to the front-panel port. The E58-CIFQ2-E USB-Serial Conversion Cable is required to connect to the front-panel port. (Do not use the product with the USB-Serial Conversion Cable left permanently connected.) Refer to the instruction manual provided with the USB-Serial Conversion Cable for details on connection methods.
- * If the front-panel port cover is lost or damaged, order it separately. The Waterproof Packing should be periodically replaced because it may deteriorate, shrink, or harden depending on the operating environment.

Names of Parts on Front Panel



- * °C / °F : temperature unit
Either 'C' or 'F' is displayed when the displayed value is a temperature.
- * Shift key (PF key)
Pressing this key operates the function that has been set on "PF Setting" of the advanced function setting level. The default PF Setting parameter is for shifting the digit.
- * Front-panel Setup Tool port:
This port is used to connect the Controller to a computer to use the Setup Tool.
- * Level key
Use this key to change levels.

- * No.1 display
Process value or set data type
- * No.2 display
Set point, set data read-out value or changed input value
- * No.3 display
Program No., segment No., segment remaining time or MV (value opening)
- * Up and Down keys
Each press of \uparrow key increments or advances the values displayed on the No.2 display. Each press of \downarrow key decrements or returns the values displayed on the No.2 display.
- * Mode key
Press this key to change the contents of the display. Press this key for 1 second or longer for reverse scroll.
- * \oplus , \ominus
Program status (the direction of change in the SP)
- * Hold the \oplus key and the \ominus key together for at least 3 seconds to switch to protect level.
- * Hold the \oplus key and the \ominus key together for at least 1 second to switch Run/Reset.

- * Operation indicators
 - SUB1 to 4: Auxiliary outputs 1 to 4 indicators
 - OUT1 to 2: Control outputs 1 to 2 indicators
 - Lit for other than 0% output for linear current output.
 - TUNE: Lit during AT (auto-tuning).
 - FSP: Lit when the Fixed SP mode is ON.
 - SP: Lit during Manual Mode.
 - HOLD: Lit during a program hold.
 - WAIT: Lit during a program wait.

Operation Menu

Input Type

Input type	Input	Setting	Setting range
Platinum resistance thermometer	Pt100	0 to -200 to 850	-300 to 1500
	1	-199.9 to 500.0	-199.9 to 900.0
	2	0.0 to 100.0	0.0 to 210.0
	3	-199.9 to 500.0	-199.9 to 900.0
Thermocouple	K	5 to -200 to 1300	-300 to 2300
	J	-6 to -200 to 500	-100 to 1500
	T	8 to -200 to 400	0.0 to 750.0
	E	11 to -200 to 600	-300 to 1100
	L	12 to -100 to 850	-100 to 1500
	U	13 to -200 to 400	-300 to 700
	N	14 to -199.9 to 400.0	-199.9 to 700.0
	R	15 to -200 to 1300	-300 to 2300
	S	16 to 0 to 1700	0 to 3000
	B	17 to 0 to 2000	0 to 3000
	W	18 to 0 to 1800	0 to 3200
	PL II	19 to 0 to 2300	0 to 3200
Infrared Thermosensor	EST1	20 to 0 to 1300	0 to 2300
	10 to 70°C	21 to 0 to 90	0 to 190
	60 to 120°C	22 to 0 to 120	0 to 240
	115 to 165°C	23 to 0 to 165	0 to 320
	140 to 200°C	24 to 0 to 260	0 to 500
Analog input type	Current input	4 to 20mA	25
	0 to 20mA	26	Use the following ranges for scaling: -1999 to 9999, -199.9 to 999.9, -19.99 to 9.99, -1.99 to 0.999
	1 to 5V	27	
	0 to 5V	28	
	0 to 10V	29	

* The default is "5". * SERR will be displayed when a platinum resistance thermometer is mistakenly connected while input type is not set for it. To clear the SERR display, correct the wiring and cycle the power supply.

Alarms

Setting	Alarm type	Alarm output function
0	No alarm function	Output off
1	Deviation upper/lower limit	ON OFF X ON OFF X Vary with "L", "H" values
2	Deviation upper limit	ON OFF X ON OFF X Vary with "L", "H" values
3	Deviation lower limit	ON OFF X ON OFF X Vary with "L", "H" values
4	Deviation upper/lower range	ON OFF X ON OFF X Vary with "L", "H" values
5	Deviation upper/lower limit standby sequence ON	ON OFF X ON OFF X Vary with "L", "H" values
6	Deviation upper limit standby sequence ON	ON OFF X ON OFF X Vary with "L", "H" values
7	Deviation lower limit standby sequence ON	ON OFF X ON OFF X Vary with "L", "H" values
8	Absolute value upper limit	ON OFF X ON OFF X Vary with "L", "H" values
9	Absolute value lower limit	ON OFF X ON OFF X Vary with "L", "H" values
10	Absolute value upper limit standby sequence ON	ON OFF X ON OFF X Vary with "L", "H" values
11	Absolute value lower limit standby sequence ON	ON OFF X ON OFF X Vary with "L", "H" values
12	LBA (only for alarm 1)	
13	PV Change Rate Alarm	
14	SP absolute value upper limit	ON OFF X ON OFF X Vary with "L", "H" values
15	SP absolute value lower limit	ON OFF X ON OFF X Vary with "L", "H" values
16	MV absolute value upper limit	ON OFF X ON OFF X Vary with "L", "H" values
17	MV absolute value lower limit	ON OFF X ON OFF X Vary with "L", "H" values

* The default alarm type is "2".

* Upper and lower limits can be set for parameters 1, 4 and 5 to provide for different types of alarms. These are indicated by the letter "L" and "H".

* Refer to the tables above for details of input types and alarm types.

* Only the value set to the "N5": Temperature Input Shift parameter is applied to the entire temperature input range. When the process value is 200°C, the process value is treated as 201.2°C after input shift if the input shift value is set to 1.2°C. The process value is treated as 198.8°C after input shift if the input shift value is set to -1.2°C.

* Operation is stopped when moved to the initial setting level. (control/alarm are both stopped.)

* The grayed-out setting items are not displayed for some models and some settings of other setting items.

Warning Symbols

CAUTION

Minor injury due to electric shock may occasionally occur.
Do not touch the terminals while power is being supplied.

Electric shock, fire, or malfunction may occasionally occur. Do not allow metal objects, conductors, cuttings from installation work, or moisture to enter the Digital Controller, the Setup Tool ports, or between the pins on the connectors on the Setup Tool cable. Attach the cover to the front-panel Setup Tool port whenever you are not using it to prevent foreign objects from entering the port.

Do not use the product where subject to flammable or explosive gas. Otherwise, minor injury from explosion may occasionally occur.

Never disassemble, modify, or repair the product or touch any of the internal parts. Minor electric shock, fire, or malfunction may occasionally occur.

CAUTION - Risk of Fire and Electric Shock

a) This product is UL listed as One-Point Process Control Equipment. It must be mounted in an enclosure that does not allow fire to escape externally.

b) More than one disconnect switch may be required to de-energize the equipment before servicing.

c) Signal inputs are SELV, limited energy.

d) Caution: To reduce the risk of fire or electric shock, do not interconnect the outputs of different Class 2 circuits.

If the output relays are used past their life expectancy, contact fusing or burning may occasionally occur.

Always consider the application conditions and use the output relays within their rated load and electrical life expectancy. The life expectancy of output relays varies considerably with the output load and switching conditions.

Loose screws may occasionally result in fire. Tighten the terminal screws to the specified torque of 0.43 to 0.58 N·m.

Set the parameters of the product so that they are suitable for the system being controlled. If they are not suitable, unexpected operation may occasionally result in property damage or accidents.

A malfunction in the Digital Controller may occasionally make control operations impossible or prevent alarm outputs, resulting in property damage. To maintain safety in the event of malfunction of the Digital Controller, take appropriate safety measures, such as installing a monitoring device on a separate line.

Safety for Use

Be sure to observe the following precautions to prevent operation failure, malfunction, or adverse effects on the performance and functions of the product. Not doing so may occasionally result in unexpected events.

Use the product within specifications.

(1) The product is designed for indoor use only. Do not use the product outdoors. Do not use or store the product in any of the following locations.

•Places directly subject to heat radiation from heating equipment.

•Places subject to liquid or oil atmosphere.

•Places subject to direct sunlight.

•Places subject to dust or corrosive gas (in particular, sulfide gas and ammonia gas).

•Places subject to icing and condensation.

•Places subject to vibration and large shocks.

(2) Use within the rated temperature and humidity ranges. Provide forced-cooling if required.

(3) To allow heat to escape, do not block the area around the product. Do not block the ventilation holes on the product.

(4) Be sure to wire properly with correct polarity of terminals.

(5) Use the shortest wires possible (M3, width 5.8 mm or less) for wiring. To connect bare wires to the terminals, use copper braided or solid wires with a gauge of AWG24 to AWG18 (equal to cross-sectional area of 0.205 to 0.821 mm²). (The stripping length is 6 to 8 mm.) Up to two wires of same size and type, or two crimped terminals can be inserted into a single terminal.

(6) Do not wire the terminals which are not used.

(7) Allow as much space as possible between the controller and devices that generate a powerful high-frequency or surge. Separate the high-voltage or large-current power lines from other lines, and avoid parallel or common wiring with the power lines when you are wiring to the terminals.

(8) Use this product within the rated load and power supply.

(9) Make sure that the rated voltage is attained within two seconds of turning ON the power using a switch or relay contact. If the voltage is not attained, the power supply may stop or output malfunctions may occur.

(10) Make sure that the Digital Controller has 30 minutes or more to warm up before turning ON the power before starting actual control operations to ensure the correct temperature display.

(11) A switch or circuit breaker should be placed close to this unit. The switch or circuit breaker should be within easy reach of the operator, and must be marked as a disconnecting means for this unit.

(12) Wipe off any dirt from the Digital Controller with a soft dry cloth. Never use thinners, benzene, alcohol, or any cleaners that contain these or other organic solvents. Deformation or discoloration may occur.

(13) Design system (control panel, etc) considering the 2 second of delay that the controller's output to be set after power-on.

(14) The controller will turn OFF when you move to the Initial Setting Level. Take this into consideration when programming control.

(15) The number of non-volatile memory write operations is limited. Therefore, use RAM write mode when frequently overwriting data during communications or other operations.

(16) When disassembling the Temperature Controller for disposal, use suitable tools.

(17) Do not connect cables to both the front-panel Setup Tool port and the top-panel Setup Tool port at the same time. The Digital Controller may be damaged or may malfunction.

(18) Do not exceed the communications distance that is given in the specifications and use the specified communications cable. Refer to the E5EC-T Digital Controllers User's Manual (Cat. No. H185) for the communications distance and cable specifications.

(19) Do not turn the power supply to the Digital Controller ON or OFF while the USB-Serial Conversion Cable is connected. The Digital Controller may malfunction.

(20) The terminals can reach temperatures of up to 75°C. Use wires with heat resistance of 75°C min to wire the terminals.

Specifications

Power supply voltage 100 to 240 VAC, 50/60 Hz or 24 VAC, 50/60 Hz / 24 VDC

Operating voltage range 85 to 110% of the rated voltage

Power consumption 8.7 VA max. (100 to 240 VAC)

Indication accuracy (Ambient temperature: 23°C) (+0.3 % of indication value or ±1°C, whichever is greater) ±1 digit max.

Platinum resistor type thermometer (+0.2 % of indication value or ±0.8°C, whichever is greater) ±1 digit max.

An